

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3725-0610:132

Page 1 of 1

CATEGORY: Door Hardware (Fire-Rated)

LISTEE: Dorma Door Controls, Drawer AC, Reamstown, PA 17567
Contact: Rick Loose (717) 336-3881 Fax (717) 336-2106

DESIGN: Models F9400, F9400LB, ESF9400 and ESF9400LB surface mounted vertical rod type fire exit hardware. This hardware consists of a concealed vertical rods, actuated top and bottom bolts and a pushbar assembly. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 80, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed fire exit hardware for use with swinging type fire doors (3/4, 1-1/2, and 3 Hrs) measuring up to 4' in width by 10' in high (single) and 8' in width by 10' in high (double) where permitted per code.

05-27-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager